



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-00698  
Inspection Number: 03651157

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER  
Job Type: Building  
Description: RS - Custom  
Scope of Work: New

### Inspection Details

Inspection Date: 09/14/2021  
Inspection Time: 7:29 AM  
Inspection Type: Insulation Thermal  
Inspection Code: 36  
Outcome: Disapproved  
Inspected By: Fredrick Mooney  
Charge Reinspection Fee: No

### Comments

requested pictures of missing vapor barrier and sill seal. Never received them.  
Do not proceed with drywall on first floor. recall thermal inspection.