Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-00698
Inspection Number: 03651484

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 09/14/2021
Inspection Time: 2:49 PM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release:
Provider: IREA
Outcome: Disapproved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No

Comments

1) pedestal end not terminated
2) identify feeder neutral per 200.6 at both ends
3) identify feeder equipment ground per 250.119 at both ends
4) intersystem bond bar required per 250.94
5) equipment ground terminal not permitted to contact neutral bar in house disconnect
6) no load connected