



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-00698  
Inspection Number: 03651484

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 5771 DISTANT VIEW PL PARKER  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 09/14/2021  
**Inspection Time:** 2:49 PM  
**Inspection Type:** Electric Service Equipment  
**Inspection Code:** 23  
**Meter Release:**  
**Provider:** IREA  
**Outcome:** Disapproved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No

### Comments

- 1) pedestal end not terminated
- 2) identify feeder neutral per 200.6 at both ends
- 3) identify feeder equipment ground per 250.119 at both ends
- 4) intersystem bond bar required per 250.94
- 5) equipment ground terminal not permitted to contact neutral bar in house disconnect
- 6) no load connected