



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-05022  
Inspection Number: 03652567

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 8061 PARADISO CT LITTLETON  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 09/20/2021  
**Inspection Time:** 11:44 AM  
**Inspection Type:** Construction Meter  
**Inspection Code:** 10  
**Meter Release:**  
**Provider:** IREA  
**Outcome:** Disapproved  
**Inspected By:** Damon Montroy  
**Charge Reinspection Fee:** No

### Comments

1. ECG required from meter to pedestal (4wire system). Bond neutral and ground at pedestal (first point of disconnect).
2. Wires must bypass meter - jumpers not allowed.
3. Remove main bond jumper from panel to separate grounds and neutral. (Float neutral at panel).
4. Address required to be marked on temp service.