



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-02361
Inspection Number: 03656590

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8099 MOUNT OURAY RD LITTLETON
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 10/05/2021
Inspection Time: 11:47 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Damon Montroy
Charge Reinspection Fee: No

Comments

1. Nail plate required in garage at south wall and SE corner.
 2. Install construction receptacle.
- Correct and proceed - will check at service inspection.