



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-02361  
Inspection Number: 03656591

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 8099 MOUNT OURAY RD LITTLETON  
Job Type: Building  
Description: RS - Stock  
Scope of Work: New

### Inspection Details

Inspection Date: 10/05/2021  
Inspection Time: 12:13 PM  
Inspection Type: Rough Frame  
Inspection Code: 29  
Outcome: Approved  
Inspected By: Robert Stratton  
Charge Reinspection Fee: No