



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-02361
Inspection Number: 03656608

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8099 MOUNT OURAY RD LITTLETON
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 10/05/2021
Inspection Time: 1:39 PM
Inspection Type: Roof Truss
Inspection Code: 127
Outcome: Cancelled
Inspected By: Fredrick Mooney
Charge Reinspection Fee: No

Comments

Complete