



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-00698  
Inspection Number: 03658398

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER  
Job Type: Building  
Description: RS - Custom  
Scope of Work: New

### Inspection Details

Inspection Date: 10/12/2021  
Inspection Time: 10:12 AM  
Inspection Type: Exterior Underground Gas Line  
Inspection Code: 32  
Outcome: Approved  
Inspected By: Richard Miller  
Charge Reinspection Fee: No

### Comments

#5665