



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-06790
Inspection Number: 03659126

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 3465 WHITFORD DR HIGHLANDS RANCH
Job Type: Building
Description: AU - Deck
Scope of Work: New

Inspection Details

Inspection Date: 10/18/2021
Inspection Time: 8:16 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Approved
Inspected By: Chris Fuller
Charge Reinspection Fee: No

Comments

Needs a continuous handrail at stairs