



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-08959

Inspection Number: 03660760

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5394 SEDONA DR PARKER

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 10/21/2021

Inspection Time: 11:00 AM

Inspection Type: Rough Frame

Inspection Code: 29

Outcome: Disapproved

Inspected By: Rick Chadwick

Charge Reinspection Fee: No

Comments

1. Minimum stand pipe at auto wash 18" 2. Seal all plate penetrations at sub floor