



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 21-06766  
Inspection Number: 03663596

## Building Inspection Report

### Permit Information

**Job Address:** 6784 AMHERST CT HIGHLANDS RANCH  
**Job Type:** Electrical  
**Description:** Other - HOT TUB INSTALL

### Inspection Details

**Inspection Date:** 11/03/2021  
**Inspection Time:** 11:33 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No

### Comments

- 1) trench inspection was not done, pothole below disconnect, at slab and in between to verify depth
- 2) hot tub side must be open for inspection of controller inside tub
- 3) #6 solid copper conductor not permitted in conduit per 310.106