



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-07504  
Inspection Number: 03666603

## Building Inspection Report

Code Reviewed Under: 2018 IBC

### Permit Information

**Job Address:** 7120 E COUNTY LINE RD # 203 1, HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** CM - Tenant Finish  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 11/15/2021  
**Inspection Time:** 1:21 PM  
**Inspection Type:** Final Plumbing  
**Inspection Code:** 40  
**Outcome:** Disapproved  
**Inspected By:** Gary Hartmann  
**Charge Reinspection Fee:** No

### Comments

Complete plenum wrap