



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-07504
Inspection Number: 03666605

Building Inspection Report

Code Reviewed Under: 2018 IBC

Permit Information

Job Address: 7120 E COUNTY LINE RD # 203 1, HIGHLANDS RANCH
Job Type: Building
Description: CM - Tenant Finish
Scope of Work: New

Inspection Details

Inspection Date: 11/15/2021
Inspection Time: 1:19 PM
Inspection Type: Final HVAC
Inspection Code: 39
Outcome: Disapproved
Inspected By: Gary Hartmann
Charge Reinspection Fee: No

Comments

Not ready, ceiling closure not approved
All tiles need to be dropped for final HVAC inspection
Provide balance report for final HVAC