



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-05022
Inspection Number: 03667072

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8061 PARADISO CT LITTLETON
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 11/16/2021
Inspection Time: 1:46 PM
Inspection Type: Electric Trench
Inspection Code: 16
Outcome: Approved
Inspected By: Damon Montroy
Charge Reinspection Fee: No

Comments

30988 and 30990
- 2 sets of
2x 350 MC AL
1x 4/0 AL
1x 1/0 AL
In a 195' trench