



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-02361
Inspection Number: 03668424

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8099 MOUNT OURAY RD LITTLETON
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 11/19/2021
Inspection Time: 11:39 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Damon Montroy
Charge Reinspection Fee: No

Comments

1. Outlets in garage and at front grade have an open neutral
2. NM exposed at AC disconnect.
3. Counter outlets on with fridge - add to description on panel schedule. Add location/description of other counter outlets at panel schedule.