

Douglas County Building Division 100 Third Street STE #20 Castle Rock, CO 80104 Phone: 303.660.7497

Email: dcbuilding@douglas.co.us

Permit Number: 21-02361 Inspection Number: 03668887

## **Building Inspection Report**

Code Reviewed Under: 2018 IRC

## **Permit Information**

Job Address: 8099 MOUNT OURAY RD LITTLETON

Job Type: Building
Description: RS - Stock
Scope of Work: New

## **Inspection Details**

Inspection Date: 11/22/2021 Inspection Time: 11:40 AM Inspection Type: Final Building

Inspection Code: 108
Outcome: Disapproved
Inspected By: Robert Stratton
Charge Reinspection Fee: No

## Comments

- 1. Rear deck ledger missing ledger locks & L90 at left end joist
- 2. Complete range hood exhaust duct
- 3. Shim water heater from rocking
- 4. Properly install AAV for floor drain
- 5. Seal bottom of basement slider
- 6. Seal hole in insulation at AC line at back walkout wall & rear sump & hose bib supply