



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-00698  
Inspection Number: 03669296

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 5771 DISTANT VIEW PL PARKER  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 11/23/2021  
**Inspection Time:** 12:34 PM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Thomas Buzo  
**Charge Reinspection Fee:** No

### Comments

- 1)IBT needs to be accessible.
- 2)Extension cords not allowed for GD openers.
- 3)breaker lock for hood.
- 4)CO detector in master bedroom when fuel burning appliances are installed within.
- 5)AFCI CB 16 not holding.