Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-00698
Inspection Number: 03669726

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5771 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 11/24/2021
Inspection Time: 10:50 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Disapproved
Inspected By: Rick Chadwick
Charge Reinspection Fee: No

Comments

1. Maximum gap at riser 4” at garage stairs 2. Caulk all water closet 3. Complete cap at guardrail and handrail
4. Minimum 30” clearance in front of water heater