



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 05-0962

Inspection Number: 02523473

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 9921 STRATFORD LN HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: New

Inspection Details

Inspection Date: 04/06/2005

Inspection Time: 3:55 PM

Inspection Type: Drywall

Inspection Code: 38

Outcome: Approved

Inspected By: Rick Chadwick

Charge Reinspection Fee: No