Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-14597
Inspection Number: 03673992

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 3778 FLAGPOLE CT CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 12/14/2021
Inspection Time: 9:10 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Thomas Buzo
Charge Reinspection Fee: No

Comments

UFER in garage

Note: Per DC amendments only 10 openings per 15A branch circuit.