Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-03666
Inspection Number: 03675622

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 7262 BUCKINGHAM PL HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 12/20/2021
Inspection Time: 11:55 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No

Comments

Dw/disposal recep won't test, has red light when test button pushed