Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 21-14597
Inspection Number: 03682087

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 3778 FLAGPOLE CT CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 01/24/2022
Inspection Time: 9:20 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Thomas Buzo
Charge Reinspection Fee: No

Comments

No more than 10 openings on 15A circuit. 13 receptacles on 15A circuit in rec room area not allowed. Noted at rough inspection 12/14/2021. Please call if you have any questions.