



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-01637  
Inspection Number: 03687137

## Building Inspection Report

### Permit Information

**Job Address:** 818 POPPYWOOD PL HIGHLANDS RANCH  
**Job Type:** Electrical  
**Description:** Service Change/Upgrade

### Inspection Details

**Inspection Date:** 02/24/2022  
**Inspection Time:** 12:21 PM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Matt Mazzara  
**Charge Reinspection Fee:** No

### Comments

1)cold water pipe GEC must terminate within first 5' of entry 250.68(C)  
2)#4cu jumper req at water meter 250.102  
3)#4cu req to bond service entrance conductor metal raceway 250.102  
4)GECs must terminate with neutral at service 250.24  
Note:talked with homeowner about electric for new FP req inspected