



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 22-01637
Inspection Number: 03687137

Building Inspection Report

Permit Information

Job Address: 818 POPPYWOOD PL HIGHLANDS RANCH
Job Type: Electrical
Description: Service Change/Upgrade

Inspection Details

Inspection Date: 02/24/2022
Inspection Time: 12:21 PM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Matt Mazzara
Charge Reinspection Fee: No

Comments

1)cold water pipe GEC must terminate within first 5' of entry 250.68(C)
2)#4cu jumper req at water meter 250.102
3)#4cu req to bond service entrance conductor metal raceway 250.102
4)GECs must terminate with neutral at service 250.24
Note:talked with homeowner about electric for new FP req inspected