



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-00473

Inspection Number: 03696086

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8449 LOST LAKE DR FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 03/29/2022

Inspection Time: 11:33 AM

Inspection Type: Underground Plumbing

Inspection Code: 12

Outcome: Approved

Inspected By: Clayton Rodeback

Charge Reinspection Fee: No