



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-02225

Inspection Number: 03696446

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 6754 LIONSHEAD PKWY LITTLETON

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 03/30/2022

Inspection Time: 11:51 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Disapproved

Inspected By: Henry VanSchaack

Charge Reinspection Fee: No

Comments

1) in-line splice device not permitted for extension of homerun to kitchen fan per 334.40

2) master bath incomplete

3) add laundry onto permit

** minimum 3 recepts required for island, will check at final **