



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-02225

Inspection Number: 03696449

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 6754 LIONSHEAD PKWY LITTLETON

**Job Type:** Building

**Description:** RS - Residential

**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 03/30/2022

**Inspection Time:** 10:58 AM

**Inspection Type:** Rough HVAC

**Inspection Code:** 27

**Outcome:** Disapproved

**Inspected By:** Anthony Frank

**Charge Reinspection Fee:** No

### Comments

1. Seal all snaplock fittings and exhaust and make up there with 181 sealant.