



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-02225

Inspection Number: 03696923

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 6754 LIONSHEAD PKWY LITTLETON

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 03/31/2022

Inspection Time: 12:54 PM

Inspection Type: Interior Gas Line

Inspection Code: 30

Meter Release: No

Provider:

Outcome: Approved

Inspected By: Anthony Frank

Charge Reinspection Fee: No

Comments

This is for the gas line to the new range.