



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-00473

Inspection Number: 03699181

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8449 LOST LAKE DR FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 04/08/2022

Inspection Time: 12:21 PM

Inspection Type: Electric Trench

Inspection Code: 16

Outcome: Approved

Inspected By: Justin Lett

Charge Reinspection Fee: No

Comments

Note-250urd w/#2 EGC ped to basement wall