



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-04087
Inspection Number: 03701857

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5720 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 04/20/2022
Inspection Time: 7:21 AM
Inspection Type: Preliminary Defensible Space
Inspection Code: 92
Outcome: Not Applicable
Inspected By: Jill Welle
Charge Reinspection Fee: No