



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-00473

Inspection Number: 03705968

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8449 LOST LAKE DR FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 05/05/2022

Inspection Time: 9:23 AM

Inspection Type: Electric Service Equipment

Inspection Code: 23

Meter Release:

Provider: CORE

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

Comments

1. Need construction meter fee paid 2. Float neutrals at temp 3. Need feeder EGC in conduit to temp sized to upstream OCPD 4. Approved meter blank 5. Bushing at connectors per 300.4 6. Protect #8 or use larger GEC