



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: [dcbuilding@douglasco.gov](mailto:dcbuilding@douglasco.gov)

Permit Number: 21-13674  
Inspection Number: 03710114

## Building Inspection Report

Code Reviewed Under: 2018 IBC

### Permit Information

**Job Address:** 2520 E COUNTY LINE RD HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** CM - Tenant Improvement  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 05/20/2022  
**Inspection Time:** 1:04 PM  
**Inspection Type:** Exterior Wall Sheathing  
**Inspection Code:** 104  
**Outcome:** Approved  
**Inspected By:** Gary Hartmann  
**Charge Reinspection Fee:** No

### Comments

Exterior sheathing can not be in contact with concrete