



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 21-13674  
Inspection Number: 03710401

## Building Inspection Report

Code Reviewed Under: 2018 IBC

### Permit Information

**Job Address:** 2520 E COUNTY LINE RD HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** CM - Tenant Improvement  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 05/20/2022  
**Inspection Time:** 11:33 AM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Approved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No

### Comments

Tower rebuild  
\*\* secure mc within 12" of sconce outlet box on east side, correct and proceed, provide pictures at next inspection \*\*