



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-05022  
Inspection Number: 03714865

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 8061 PARADISO CT LITTLETON  
Job Type: Building  
Description: RS - Custom  
Scope of Work: New

### Inspection Details

Inspection Date: 06/09/2022  
Inspection Time: 6:56 AM  
Inspection Type: Rough Electric  
Inspection Code: 22  
Outcome: Approved  
Inspected By: Matt Mazzara  
Charge Reinspection Fee: No

### Comments

Note:ded 15amp circuit provided for bsmt electric FP. If 1500 watts or more req 20amp circuit