



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-05022
Inspection Number: 03716413

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8061 PARADISO CT LITTLETON
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 06/14/2022
Inspection Time: 10:45 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Approved
Inspected By: Robert Stratton
Charge Reinspection Fee: No

Comments

1. Install 2 anchor bolts per plate in garage
2. Anchor bolts needed within 12" of all plate breaks or ends
3. Strap top plate back right garage corner
4. Roof vents not installed
5. Nail all garage corners 3 nails 24" oc
6. Nail ALL exterior corners 3 nails 24" oc
7. Remove float blocks basement
8. Ok to insulate