



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 21-05022
Inspection Number: 03718076

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8061 PARADISO CT LITTLETON
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 06/20/2022
Inspection Time: 10:46 AM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Approved
Inspected By: Robert Stratton
Charge Reinspection Fee: No