



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-05022  
Inspection Number: 03718205

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 8061 PARADISO CT LITTLETON  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 06/21/2022  
**Inspection Time:** 1:55 PM  
**Inspection Type:** Electric Service Equipment  
**Inspection Code:** 23  
**Meter Release:** Yes  
**Provider:** CORE  
**Outcome:** Approved  
**Inspected By:** Rick Sugar  
**Charge Reinspection Fee:** No

### Comments

- 1) Intersystem bonding terminal bar required at final
- 2) UFER located NW corner of basement BR