



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 21-05022  
Inspection Number: 03719122

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 8061 PARADISO CT LITTLETON  
Job Type: Building  
Description: RS - Custom  
Scope of Work: New

### Inspection Details

Inspection Date: 06/23/2022  
Inspection Time: 11:32 AM  
Inspection Type: Moisture Barrier  
Inspection Code: 53  
Outcome: Approved  
Inspected By: Robert Stratton  
Charge Reinspection Fee: No