



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-00473

Inspection Number: 03731133

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 8449 LOST LAKE DR FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

### Inspection Details

Inspection Date: 08/08/2022

Inspection Time: 9:42 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

### Comments

1. High recep in RV garage cannot be on bay circuit 2. Lower level exterior lights and receps incomplete 3. Staple in laundry and basement ceiling 4. Runners at NM within 6' of access

Note-floor heat requires inspection and cannot be located in closets