



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-00473

Inspection Number: 03731646

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

Job Address: 8449 LOST LAKE DR FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

### Inspection Details

Inspection Date: 08/09/2022

Inspection Time: 12:03 PM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

### Comments

Corrections from previous inspection incomplete-please note that upper hall smoke alarm is required to be at least 3' horizontally from bathroom door that contains shower or tub-missed getting this on last inspection report