



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-02225

Inspection Number: 03733524

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 6754 LIONSHEAD PKWY LITTLETON

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 08/16/2022

Inspection Time: 11:11 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Approved

Inspected By: Henry VanSchaack

Charge Reinspection Fee: No

Comments

Master bath

** 3 lights added to existing circuit, unable to verify maximum 10 openings per 15a circuit, will check at final **