



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-02225

Inspection Number: 03733525

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 6754 LIONSHEAD PKWY LITTLETON

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 08/16/2022

Inspection Time: 10:13 AM

Inspection Type: Rough Frame

Inspection Code: 29

Outcome: Approved

Inspected By: Chris Fuller

Charge Reinspection Fee: No

Comments

Did rough for bath and kit