



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-03623
Inspection Number: 03738582

Building Inspection Report

Code Reviewed Under: 2012 IBC

Permit Information

Job Address: 922J PAWNEE TRL CASTLE ROCK
Job Type: Building
Description: CM - Cell Site
Scope of Work: Alteration

Inspection Details

Inspection Date: 08/31/2022
Inspection Time: 9:42 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No