



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 21-06545  
Inspection Number: 03738644

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 253 STONE POINTE TRL CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 09/01/2022  
**Inspection Time:** 12:17 PM  
**Inspection Type:** Electric Trench  
**Inspection Code:** 16  
**Outcome:** Approved  
**Inspected By:** Rick Sugar  
**Charge Reinspection Fee:** No

### Comments

1) Trench is approximately 130', from the Core pedestal to the E side of the house, (2) runs of 4/0 and (2) #2 EGCs