



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-03623
Inspection Number: 03738739

Building Inspection Report

Code Reviewed Under: 2012 IBC

Permit Information

Job Address: 922J PAWNEE TRL CASTLE ROCK
Job Type: Building
Description: CM - Cell Site
Scope of Work: Alteration

Inspection Details

Inspection Date: 08/31/2022
Inspection Time: 9:42 AM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release: Yes
Provider: CORE
Outcome: Approved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No

Comments

** arc flash labels required per 110.16 for final **
** fault current label required per 110.24 for final **
** final inspection required (building and electric) when power is energized **