



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 17-12027  
Inspection Number: 03739954

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 9125 CORRAL LN CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Basement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 09/07/2022  
**Inspection Time:** 9:57 AM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Disapproved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No

### Comments

\*\* 2017 NEC \*\*

- 1) pull all devices out of outlet boxes and leave hanging for inspection
- 2) secure nm within 12" of all recess cans, within 8" of recep boxes
- 3) recep required within 6' of left side of closet door in north bedroom