



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-12027
Inspection Number: 03739954

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9125 CORRAL LN CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/07/2022
Inspection Time: 9:57 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No

Comments

** 2017 NEC **

- 1) pull all devices out of outlet boxes and leave hanging for inspection
- 2) secure nm within 12" of all recess cans, within 8" of recep boxes
- 3) recep required within 6' of left side of closet door in north bedroom