



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-12027
Inspection Number: 03739955

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9125 CORRAL LN CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/07/2022
Inspection Time: 11:10 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Disapproved
Inspected By: Clayton Rodeback
Charge Reinspection Fee: No

Comments

Complete fire blocking/draft stopping as discussed.
Leave fireplace framing open for inspection of B vent.
Note: Bathroom water closet room does not meet minimum 30 inch wide clearance due to existing location.
OK to recall with insulation