



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 22-04680
Inspection Number: 03742640

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2701 CASTLE PINES DR NORTH CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/15/2022
Inspection Time: 11:58 AM
Inspection Type: Drywall
Inspection Code: 38
Outcome: Approved
Inspected By: Nick Martinell
Charge Reinspection Fee: No