



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-00473

Inspection Number: 03743767

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 8449 LOST LAKE DR FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 09/20/2022

Inspection Time: 2:04 PM

Inspection Type: Slab Electrical

Inspection Code: 73

Outcome: Approved

Inspected By: Thomas Buzo

Charge Reinspection Fee: No

Comments

Heat sensors not installed at time of inspection. Note: sensor wire shall maintain 1" clearance from heat cables.

In-floor heat at laundry, bath by garage, master bath and JJ bath.